

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by ...PHED Lab Grandnagar
(Name of Officers with designation) from ...Superintending Chemist PHED Lab
inspected the ...St. Anselm's Sr. Sec. School Sambhar Phulera

(Name & Address of the school) on 29/1/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 30 dated 29/1/25

of Grandnagar Lab (PHED Lab) certified that the

St. Anselm's Sr. Sec. School Sambhar Phulera (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal: सहायक अभियन्ता

Name : जन. स्व. अभि. विभाग

Designation : मुख्य संचालक

Name & Address of the Office / Department :

To

St. Anselm's Sr. Sec.
School Sambhar Phulera
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, RAJASTHAN, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Report No.: Raj/DW(Chem)/2024-25/ 4042

The sample was not collected
by this laboratory

Dated: 20/1/2025

Issued To,

Principal, St. Anselms Sr. Sec. School
Sambhar Road,
Phulera

Not Valid for Water
Quality Legal Cases

District: Jaipur
Block/City: Sambhar

Ref ID :	23	Lab Sample No. :	30
Reference : Your Letter No.:	.	Source :	Treated
Reference Dated :	27-01-2025	Source Location :	Campus of St. Anselms School
Date of Receipt :	27-01-2025	Habitation/Ward No. :	Bhadarpura
Name of Sample Taker :	Ranjil Josaf	Village/Colony/Town :	Bhadarpura
Desig. of Sample Taker :	-	Gram Panchayat/City Area :	Phulera
Latitude :		Date of Collection :	27-01-2025
Longitude :		Date of Examination :	28-01-2025
Elevation in Meter :			
IS-10500:2012			
Test Parameters	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	Test Values of Samples
1 pH	6.5 to 8.5	No Relaxation	7.8
2 Turbidity(NTU)	1	5	Clear
3 Colour (Hazen Unit)	5	15	None
4 Odour	Unobjectionable	-	UO
5 Total Alkalinity (as CaCO ₃)	200	600	100
6 Total Hardness (as CaCO ₃)	300	600	40
7 Calcium (as Ca++)	75	200	8
8 Magnesium (as Mg++)	30	100	5
9 Chloride (as Cl ⁻)	600	1000	30
10 Sulphate (as SO ₄ ⁻²)	200	400	13
11 Nitrates (as NO ₃)	45	No Relaxation	9
12 Fluoride (as F ⁻)	1.0	1.50	0.16
13 Total Dissolved Solids	500	2000	280
14 Residual Chlorine	0.2	0.5	Nil

Note:- Report is not valid for Food Licence or any Certificate.

Superintending Chemist
PHED, Lab, Jaipur
Dated:

Report No.: Raj/DW(Chem)/2024-25/

Copy to:

1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

0

Principal
St. Anselm's School
Sambhar Road, PHULERA
JAIPUR (Raj.)

Manager
St. Anselm's School
Sambhar Road, PHULERA
JAIPUR (Raj.)

Superintending Chemist



**PUBLIC HEALTH ENGINEERING DEPARTMENT
(SAMBHAR LAKE, JAIPUR)**


**PERFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITIONS CETIFICATE**


No 100


Date: 24/07/2024

It is certified that an inspection team headed by Om Prakash Verma (JEN) from P.H.E.D
Smbhar Lake (Jaipur) inspected the St. Anselm's School, Sambhar Road, Phulera
on 24/07/2024 and found that the St. Anselm's School, Sambhar Road, Phulera has
sate drinking water facilities for the students and members of staff of the institution and is
maintaining the hygienic sanitation condition in the school building and
the campus as per the norms prescribed by the Central / State / U.T. Govt.

The above certificate is valid for a period of.....3 years.....


Principal
St. Anselm's School
Sambhar Road, PHULERA
JAIPUR (Raj.)


(Om Prakash Verma)
कमिष्ठ अभियन्ता
जन.स्वा.अधि. विभाग
अनुभाग समिर रोड


Manager
St. Anselm's School
Sambhar Road, PHULERA
JAIPUR (Raj.)